

## Erin Bevis-Carver

---

**From:** Lalit Sharma  
**Sent:** Tuesday, June 21, 2016 1:41 PM  
**To:** Frasier, Douglas (DEQ) (Douglas.Frasier@deq.virginia.gov)  
**Cc:** Erin Bevis-Carver; William Skrabak; Rachel Stradling; lydia.zweimiller@vdh.virginia.gov  
**Subject:** CSS Overflow

Doug:

This is to follow-up on the voicemail I left for you with the report of a dry weather overflow on Outfall 003 (@ King and West) of City's combined sewer system. The overflow was observed at 9:40 AM this morning (June 21, 2016) during routine twice/month inspection. Operations staff immediately responded, took corrective actions, and overflow completely abated by 11:40 AM. Although exact volume of overflow is not known/estimated at this time, but, overflows did make it to Hooffs Run as a result of this episode.

Staff is investigating the incident further, and will follow-up with more information and corrective action in its 5-day letter.

Thanks, and please feel free to contact me should you have any questions.

Lalit Sharma, P.E.  
Division Chief, Sanitary Infrastructure  
Transportation and Environmental Services  
City of Alexandria  
Phone: 703-746-4072  
Fax: 703-519-8354



In keeping with Eco-City Alexandria please consider the environment before printing this e-mail.